



CITY OF ADA  
A Municipal Corporation

---

Michael Wicker  
City Engineer  
231 South Townsend  
Ada, Oklahoma 74820-6443  
580-436-6300 x 255

October 1, 2025

Dear Prospective Proposers:

Re: GENERATOR 1,000KW WITH CONTROLS AND ATS

Please find attached Addendum No. 1 for the above referenced project. **Prospective bidders shall sign Addenda and submit Addenda in the Bid Proposal to acknowledge receipt in order for Bid to be acknowledged as responsive.**

If you have any questions or concerns please contact me at your earliest convenience.

Respectfully Submitted,

Michael Wicker, P.E.  
City Engineer



CITY OF ADA  
A Municipal Corporation

Michael Wicker  
City Engineer  
231 South Townsend  
Ada, Oklahoma 74820-6443  
580-436-6300 x 255

GENERATOR 1,000KW WITH CONTROLS AND ATS BID


ADDENDUM NO. 1

**TO: All Prospective Bidders**

The Contract Documents for the above referenced project is hereby modified as follows:

1. Clarification: The ATS shall be rated at a 1500 Amp minimum. Please note that Bids are evaluated on a best buy basis and will be determined by the spec qualification, price, and delivery time. The Delivery time will need to reflect the lead time for the Generator and ATS.

ADDENDUM NO. 1 ISSUED BY:

  
Michael Wicker, P.E.  
City Engineer 10/1/15

---

**Acknowledgement of Addenda**

---

Bidder's Representative

---

Title